# GE Energy Connections

# Model 465

## Voltage Transformer

### Application

60 Hz.

# Standard Secondary Voltage

120 Volts.

#### **Insulation Level**

600 Volt, 10 kV BIL full wave.

### Accuracy Class:

0.6 W, 1.2 X at 60 Hz.

## Thermal Rating:

150 VA at 30 °C. amb. 100 VA at 55 °C. amb.

Terminals are brass studs No. 10-32 with one lockwasher, flatwasher and regular nut.

Approximate weight 7.75 lbs.






#### Model 465

Catalog Number	Voltage Ratio	Turns Ratio	Rec. Primary Fuse rating
465—069	69.3:120	0.58:1	5.0
465—120	120:120	1:1	4.0
465-208	208:120	1.73:1	2.0
465-240	240:120	2:1	2.0
465—277	277:120	2.31:1	2.0
465-288	288:120	2.4:1	1.5
465-300	300:120	2.5:1	1.5
465—346	346:120	2.88:1	1.5
*465—480	*480:120	4:1	1.0
*465-600	*600:120	5:1	0.75



#### Model 465

- The core and coil assembly is encased in a thermoplastic shell and filled with resin.
- These transformers are designed for operation line-to-line. They may also be operated line -to-ground or line-to-neutral at reduced voltage voltage, (58% of rated volts).
- It is desirable to use a 1.6 amp fuse in the secondary to protect the transformer.
- With two exceptions these transformer are ANSI C57.13 group 1. Those marked \* are group 2.
- Models designed specifically for 50Hz operation are available with reduced performance. Consult factory for details.
- This page contains a circle diagram for the estimation of the errors for other than rated burdens. See page 27 in this section for a description of its use.
- Each transformer has two plastic terminal cover.



#### GEGridSolutions.com

Grid-AIS-L4-ITI\_Model\_465-1420-2017\_05-EN. General Electric Company and Instrument Transformers LLC reserve the right to change specifications of described products at any time without notice and without obligation to notify any person of such changes.

#### Worldwide Contact Center

Web: www.GEGridSolutions.com/contact Phone: +44 (0) 1785 250 070 USA and Canada: +1 (0) 800 547 8629 Europe, Middle East and Africa: +34 (0) 94 485 88 00

